

COMMONLY FOUND FIRE SAFETY VIOLATIONS

IMPROPER STORAGE

1A	Combustibles stored within 18" of sprinklers
1B	Combustibles stored within 24" of unsprinklered ceiling
1C	Outdoor combustible storage height greater than 20 feet
1D	Fueled equipment stored/operated/repared in unapproved building
1E	Combustible materials in exit/enclosure/stairways
1F	Combustibles materials stored in mechanical/electrical room
1H	Compress gas cylinders not properly secured in upright position
1J	Dumpster stored less than 10' from combustibles (walls, roof, etc.)
1K	Storage over 12' without proper fire protection system
1L	High piled combustible storage without permit

FIRE PROTECTION SYSTEMS (cont)

5I	FDC blocked or obstructed
5J	Fire hydrant blocked or obstructed (3' clear space)
5K	Private hydrant not maintained or annually inspected
5L	Ceiling tiles missing
5M	Holes in draft stops or fire resistive assembly
5Q	Sprinkler placard & valves not labeled
5R	Fire protection system yellow or red tagged
5T	Sprinkler riser room/fire alarm control room not labeled
5U	No access to sprinkler riser room & fire alarm control room
5V	FDC not labeled
5W	Locking FDC caps required
5X	Fire alarm system required
5Y	Spare sprinkler heads & wrench not stored in cabinet

FIRE EXTINGUISHERS

2A	Portable extinguisher not installed as required
2B	Extinguisher not mounted in conspicuous location
2C	Extinguisher requires service
2D	Class K extinguisher not installed with kitchen hood system
2E	2A/20BC extinguisher not installed at service (gas) station

HAZARDOUS MATERIALS

6A	Hazardous materials in excess of quantities allowed without permit
6C	Chemical specific hazardous material code violation
6D	Hazardous material labeling not provided
6G	Vehicular impact protection not provided
6H	Flammable liquids over 10 gallons not in approved storage cabinet
6U	Improper storage/use of propane

EXIT AND LIGHTING REQUIREMENTS

3A	Required exit obstructed or locked
3B	Exit sign not installed or illuminated
3D	Non-approved locking device on exit door
3E	Exit door not maintained
3F	Exit discharge area obstructed
3G	Emergency lighting not installed or maintained as required
3H	Emergency power for exit signs not maintained as required
3I	No panic hardware on exit door where required
3J	Exit illumination not maintained

SERVICE (GAS) STATIONS

7A	Emergency pump shut off not marked or visible from pumps
7D	Nozzles or hoses not properly maintained
7E	No smoking/stop engine/no unapproved containers signs not posted
2E	2A/20BC extinguisher not installed at service (gas) station

GENERAL FIRE SAFETY

ELECTRICAL HAZARDS

4B	Improper use of extension cords
4D	Electrical boxes lack covers as required
4E	Electrical appliance not listed by approved agency
4F	Improper use of decorative lighting (90 day maximum)
4G	Improper use of power strips
4H	Access to electrical panel not maintained (30" x 36" x 72")
4I	Wiring not maintained in good condition
4J	Abandoned wire or cable not removed

8A	Gas meter/regulator/piping exposed to vehicle damage
8B	Vacant building not maintained as required on unsecured
8C	Approved address numbers not visible from street front
8D	Fire access road obstructed
8F	BBQ pits/cooking appliances used or stored improperly
8G	Overcrowding/occupant load exceeding approved capacity
8H	Fireworks violation
8J	Key box/switch or keys required for access issue
8K	Fire lanes not maintained
8M	Swimming pool not adequately secured or safeguarded

FIRE PROTECTION SYSTEMS

5A	Kitchen hood grease removal fans and ducts not clean
5B	Kitchen extinguishing system requires service (every six months)
5C	Fire alarm system not annually tested
5D	Sprinkler system not received annual testing
5E	Smoke or other alarm system inoperative or missing
5F	Damaged or painted sprinkler heads (must be replaced)
5G	Sprinkler valves not supervised
5H	FDC not operational or capped